

CERTIFICATE of Conformity



Registration No.: A3 50665623 0001

Report No.: CN24M7SL 001

Holder: NINGBO DEYE ESS TECHNOLOGY CO., LTD
No.568, South Rixian Road,
Binhai Economic Development Zone,
Cixi, Ningbo,
Zhejiang
P.R. China

Product: Energy Storage System
(All-in-one Energy Storage System)

Identification: Type Designation : RW-F5.1-2H2 , RW-F5.1-1H2
RW-F5.3-2H3 , RW-F5.3-1H3
Firmware version : V3A87
Serial Number : 2407250926
Remark(s) : Refer to test report CN24M7SL 001
for details.

Tested acc. to: EN 50549-1:2019+A1
EN 50549-10:2022

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Durch die DAkkS nach
DIN EN ISO/IEC 17065:2013
akkreditierte Zertifizierungsstelle.
Die Akkreditierung gilt nur für den in der
Urkundenanlage D-ZE-14169-01-02
aufgeführten Akkreditierungsumfang.

Certification Body

Date 04.03.2025

A. Chen



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Certificate No.: A3 50665623 0001

Certificate Of Conformity

License holder: NINGBO DEYE ESS TECHNOLOGY CO., LTD
No.568, South Rixian Road,
Binhai Economic Development Zone,
Cixi, Ningbo,Zhejiang
P.R. China

Type of product: Energy Storage System
(All-in-one Energy Storage System)

Model: RW-F5.1-2H2 , RW-F5.1-1H2
RW-F5.3-2H3 , RW-F5.3-1H3

Firmware version: V3A87


Standard: **EN 50549-1: 2019+A1**
Requirements for generating plants to be connected in parallel with distribution networks - Part 1: Connection to a LV distribution network - Generating plants up to and including Type B
EN 50549-10:2022
Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Report No.: CN24M7SL 001

Date of issue: 04.03.2025

The verification of conformity refers to the above mentioned product. This is to verify that the specimen is in conformity with the assessment requirement mentioned above. This verification does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.


A. Chen
Certifier



Certificat n°.: A3 50665623 0001

Certificat de conformité

Titulaire de la licence: NINGBO DEYE ESS TECHNOLOGY CO., LTD
No.568, South Rixian Road,
Binhai Economic Development Zone,
Cixi, Ningbo, Zhejiang
P.R. China

Type de produit: Energy Storage System
(All-in-one Energy Storage System)

Modèle: RW-F5.1-2H2 , RW-F5.1-1H2
RW-F5.3-2H3 , RW-F5.3-1H3

Version du firmware: V3A87

Standard: **EN 50549-1 : 2019+A1**
Exigences relatives aux centrales électriques destinées à être raccordées en parallèle à des réseaux de distribution - Partie 1: Raccordement à un réseau de distribution BT - Centrales électriques jusqu'au Type B inclus
EN 50549-10 : 2022
Exigences relatives aux centrales électriques destinées à être raccordées en parallèle à des réseaux de distribution - Partie 10 : Essais pour l'évaluation de la conformité des unités de production

Rapport n°. : CN24M7SL 001

Date d'émission : 04.03.2025

La vérification de la conformité concerne le produit susmentionné. Elle a pour but de vérifier que le spécimen est conforme aux exigences d'évaluation mentionnées ci-dessus. Cette vérification n'implique pas l'évaluation de la fabrication du produit et ne permet pas l'utilisation d'une marque de conformité de TÜV Rheinland.


A. Chen
Certifier

